
# SOUTHERN UTAH UNIVERSITY CENTRUM CONCOURSE DOOR REPLACEMENT



State of Utah-Department of Administrative Services

## AND MANAGEMENT

4110 State Office Building/Salt Lake City, Utah 84114/538-3018

## CODE ANALYSIS A

#### APPLICABLE CODES Y*e*ar 2006 National Electrical Code International Mechanical Code 2006 Uniform Code for 2006 Building Conservation 2006 ADA Accessibility Guildelines

Occupancy and Group:

International Building Code

International Plumbing Code

International Fire Code

International Energy

Conservation Code

A4 OCCUPANCY AT TIME OF CONSTRUCTION ORIGINAL CONSTRUCTION 1984

Change in Use: Yes \_\_\_\_ No X\_\_\_ Mixed Occupancy: Yes \_\_\_\_ No \_\_X\_\_\_ Special Use and Occupancy (e.g. High Rise, Covered Mall): N/A

- Seismic Design Category:
  - N/A
- Type of Construction (circle one):
- D. Fire Resistance Rating

Requirements for the Exterior Walls based on the fire separation distance (in hours):

North: <u>O\_\_\_\_\_</u> South: <u>O\_\_\_\_\_</u>

East: <u>O\_\_\_\_</u> West: <u>O</u>\_\_\_\_

E. Mixed Occupancies: N/A

Nonseparated Uses: <u>N/A</u>\_\_

F: Sprinklers:

Required: EXISTING Provided: EXISTING Type of Sprinkler System: N/A

- G: Number of Stories: N/A Building Height: N/A
- H: Actual Area: 34,972 SQUARE FEET

Tabular Area: N/A - SQUARE FOOTAGE DOESN'T CHANGE Area Modifications:

Frontage Increase:

Sum of the Ratio Calculations for Mixed Occupancies:

Actual Area

- Total Allowable Area for:
- One Story: A (1) N/A
- Тшо Story: А (2)\_<u>N ∕ А</u>\_\_ Three Story: A (3)N/A
- Unlimited Area Building: Yes N/A No \_\_\_\_\_

Κ.	Fire	Resistance	Rating	Requirements	for	Building	Elements	(hours

E×	Element	Hours	Assembly Listing	Element	Hours	Assembly Listing
	Exterior Bearing Walls	0		Floors - Ceiling Floors Roofs - Ceiling Roofs Exterior Doors and Windows Shaft Enclosures Fire Walls Fire Partitions Smoke Partitions	0	
	Interior Bearing Walls	0			0	
	Exterior Non-Bearing	0			0	
	Walls	0			0	
	Structural Frame	0			0	
		0			0	
	Fire Barriers	0			0	
					0	

Design Occupant Load: \_\_\_\_\_\_ ARENA - 5.000 SEATING CAPACITY BUILDING WITH ARENA - 5, 100

Exit Width Required:

ARENA TO CONCOURSE - 150 INCHES BUILDING TO EXTERIOR - 855 INCHES

Exit Width Provided:

EXISTING ARENA TO CONCOURSE -1.008 INCHES EXISTING BUILDING TO EXTERIOR -1,476 INCHES

- M. Minimum Number of Required Plumbing Facilities:
  - NO CHANGE TO RESTROOMS a) Water Closets - Required (m) N/A (f) N/AProvided (m) N/A (f) N/A
  - b) Lavatories Required (m) N/A (f) N/AProvided (m) N/A (f) N/A
  - c) Bath Tubs or Showers: N/A
  - d) Drinking Fountains:  $\frac{N/A}{}$ Service Sinks: N/A

ALL DOORS AND DOOR HARDWARE TO COMPLY WITH GOVERNING CODES AND ADA REQUIREMENTS

### FOOTNOTES:

- IN CASE OF CONFLICT WITH THE U.S. DEPARTMENT OF JUSTICE FEDERAL REGISTERS, ADA GUIDELINES AND SPECIFIC REFERENCE TO THE INTERNATIONAL BUILDING CODE ACCESSIBILITY CHAPTERS, THE MORE RESTRICTIVE REQUIREMENTS SHALL GOVERN.
- ADDITIONAL CODE INFORMATION SHALL BE PROVIDED AT THE DISCRETION OF THE BUILDING OFFICIAL FOR COMPLEX BUILDINGS. INCLUDING, BUT NOT LIMITED TO:

  A) HIGH RISE REQUIREMENTS.
  B) ATRIUMS.
  C) PERFORMANCE BASED CRITERIA.
  D) MEANS OF EGRESS ANALYSIS.
  E) FIRE ASSEMBLY LOCATION SHEET.
  F) EXTERIOR AND INTERIOR ACCESSIBILITY ROUTE.
  G) FIRE STOPPING. (INCLUDING TESTED DESIGN NUMBER.)

SHEET INDEX

COVER SHEET AND SHEET INDEX

G1.01 A2.10 FLOOR PLAN FLOOR PLAN - EXISTING EGRESS A2.20

Sheet Title: COVER SHEET

Revisions:

CODE REVIEW 10.22.08


PROJECT NUMBER: 08525 DRAWN BY: CHECKED BY:

J.C.S. APPROVED BY: J.C.S.

09.22.08

J.C.S.





Sheet Title: FLOOR PLAN


CODE REVIEW 10.21.08

PROJECT NUMBER: 08525 09.22.08

DRAWN BY: J.C.S. CHECKED BY: J.C.S. J.C.S.

A2.10

SHEET NUMBER:



FLOOR PLAN -EXISTING EGRESS

CODE REVIEW 10.22.08 2 CODE REVIEW 10.27.08

A2.20